



477 Temperance Street | St. Paul, MN 55101 | (651) 286-8450

## **Memorandum**

**To:** *Mark Casey, City Manager*  
*Jay Hartman, Public Works Director*

**From:** *Erin Heydinger, WSB & Associates, Inc.*

**Date:** *April 28, 2017*

**Re:** *Weekly Update for Advanced Oxidation Water Treatment Plant*  
*WSB Project No. 2170-29*

---

This week, the new booster station was started-up by the pump manufacturer. The sprinkler system was finished and started up in the peroxide room of the AOP building. The electrician is continuing to pull wires to the Trojan UV units. The UV unit supplier and manufacturer were on-site repairing a leak in the one of the UV units. The final site grading is underway.