



477 Temperance Street | St. Paul, MN 55101 | (651) 286-8450

Memorandum

To: *Mark Casey, City Manager*
Jay Hartman, Public Works Director

From: *Erin Heydinger, WSB & Associates, Inc.*

Date: *June 2, 2017*

Re: *Weekly Update for Advanced Oxidation Water Treatment Plant*
WSB Project No. 2170-29

Over the past week, the contractor has continued to perform site work, including grading and laying the base for the new driveway to the AOP Plant. The generator was load bank tested last week to ensure it can handle the required loads; it passed the test. Permanent power is now available at the AOP Plant. The contractor's electrician is continuing to connect the AOP cables in the reactor room. Trojan, the UV Reactor supplier, will be on-site soon to configure the units before plant start-up.