



477 Temperance Street | St. Paul, MN 55101 | (651) 286-8450

Memorandum

To: *Mark Casey, City Manager*
Jay Hartman, Public Works Director

From: *Erin Heydinger, WSB & Associates, Inc.*

Date: *June 21, 2017*

Re: *Weekly Update for Advanced Oxidation Water Treatment Plant*
WSB Project No. 2170-29

Trojan has been on-site this week testing the UV oxidation equipment and preparing for system start-up. The contractor's painters have been removing the insulation from the ground storage reservoir, which will ultimately be replaced. Painters have also been working inside the AOP building on coating the piping system. They hydrogen peroxide tanks were filled by the chemical company. City staff have been busy getting trained in on all the new equipment.