



477 Temperance Street | St. Paul, MN 55101 | (651) 286-8450

## **Memorandum**

**To:** *Mark Casey, City Manager*  
*Jay Hartman, Public Works Director*

**From:** *Erin Heydinger, WSB & Associates, Inc.*

**Date:** *July 19, 2017*

**Re:** *Weekly Update for Advanced Oxidation Water Treatment Plant*  
*WSB Project No. 2170-29*

---

Trojan is on site this week starting up the AOP plant and determining the correct hydrogen peroxide dosage. Substantial completion for the project is on Friday, July 21, which means that the plant will be operational at that point. The well driller is continuing to work on properly sealing old City Well No. 1. It is likely that the well will need to be drilled out and removed. The ground storage reservoir rehabilitation is continuing; the caulking is being replaced prior to re-insulation. The site will be seeded and black top will be laid within the next two weeks.